



# 2023

## WATER QUALITY REPORT

---

**MORNINGSTAR**



Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

# TABLE OF CONTENTS

## 2 | TABLE OF CONTENTS

WELCOME  
YOUR WATER  
2023 RESULTS  
MORE INFO

### About Your Water Quality

At New Mexico Water Service (New Mexico Water), our goal is to deliver safe, high-quality drinking water, 24 hours per day, seven days per week, 365 days per year. As part of that effort, we produce this annual water quality report, which includes information about where your water comes from, what it contains, and how it compares to state and federal standards. **Most importantly, it confirms that in 2023, our water met or surpassed all standards set by the U.S. Environmental Protection Agency (EPA) and New Mexico Environment Department to protect public health.**

### YOUR WATER SYSTEM

Possible Contaminants  
PFAS  
About Lead


### YOUR 2023 RESULTS

Table Introduction  
Water Quality Table  
Important Information About  
Your Drinking Water

### THANK YOU



# YOUR WATER SYSTEM



The Morningstar system consists of a consecutive connection to the City of Farmington, which consists of a master meter and a reduced-pressure principle backflow assembly. The water is piped to the Farmington pumping station, which consists of two 10,000-gallon storage tanks and four manually operated booster pumps. From there, it is pumped to the Star Heights storage and pump station while serving customers tied into the delivery line along the way.

## **SOURCE WATER ASSESSMENT AND PROTECTION**

New Mexico Water Service is currently working with the New Mexico Environmental Department on developing a Source Water Protection Plan for the Morningstar Water System.

## **FOR DETAILS ON THE DATA IN THIS REPORT**

New Mexico Water Service  
Attn: Staci Avendano  
608 Butte Boulevard  
Elephant Butte, NM 87935  
(575) 744-5974  
[SAvendano@newmexicowater.com](mailto:SAvendano@newmexicowater.com)

If you would like more information or have questions about your water service, please contact us:

608 Butte Boulevard  
Elephant Butte, NM 87935  
(575) 744-5974  
M–F 10 a.m.–5 p.m.  
(closed noon–1 p.m.)



# POSSIBLE CONTAMINANTS

**All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants.**

**The presence of contaminants does not necessarily indicate that water poses a health risk.**

The sources of drinking water (both tap and bottled) include rivers, lake, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals—and in some cases radioactive material—and can pick up substances resulting from the presence of animals or human activities. Prior to entering the distribution system, source water with constituents over maximum contaminant levels is treated to reduce levels to meet standards set by public health experts.

More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at (800) 426-4791.

## **Contaminants that may be present in source water include:**

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic compounds, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems.
- Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations also establish limits for contaminants in bottled water, which must provide the same protection for public health.

## PFAS

Per- and polyfluoroalkyl substances (PFAS) are manmade compounds that have been used to make carpets, clothing, fabrics for furniture, paper packaging for food, and other materials (e.g., cookware) that are resistant to water, grease, or stains. These compounds are also used for firefighting at airfields, which is one way they have found their way into groundwater in certain areas.

In March 2023, EPA issued a proposed national primary drinking water regulation for certain PFAS. The proposed regulation calls for a maximum contaminant level for PFOS and PFOA of 4 ppt each. Four additional PFAS—PFNA, PFHxS, PFBS, and GenX—would have a combined hazard index limit of 1.0; the hazard index calculation would determine if the levels of these PFAS as a mixture pose a potential risk.

Studies indicate that long-term exposure to PFAS over certain levels could have adverse health effects, including developmental effects to fetuses during pregnancy or infants; cancer; or impacts on liver, immunity, thyroid, and other functions. Potential health effects related to PFAS are still being studied, and research is still evolving on this issue.

While we are doing our part to treat the water and meet the standards public health experts have set, it's important that our population as a whole focuses on being good stewards of the environment and takes steps to prevent impacting the water supply.

## ABOUT LEAD

As the issue of lead in water continues to be top of mind for many Americans, New Mexico Water wants to assure you about the quality of your water.

*None of these conditions exist at New Mexico Water.* We have worked proactively to eliminate lead-bearing materials from our water systems, and we are compliant with health and safety codes mandating the installation of lead-free materials in public water systems. We test our water sources to ensure that the water we deliver to customers' meters meets water quality standards and is not corrosive toward plumbing materials. The water we deliver may meet lead standards, but what about your home plumbing? Because lead in drinking water comes primarily from materials and components associated with service lines and home plumbing, the Lead and Copper Rule is a critical part of our water quality monitoring program.

The Lead and Copper Rule requires us to test water *inside* a representative number of homes with plumbing most likely to contain lead and/or lead solder (those built before 1986). This test, with other water quality testing,

tells us if the water is corrosive enough to cause lead from home plumbing to leach into the water. If the "Action Level" for lead is exceeded, we work with our customers to investigate the issue and, if necessary, implement corrosion control before the lead levels create a health issue.

Elevated levels of lead, if present, can cause serious health problems, especially for pregnant women and children. If your home's plumbing contains lead piping or pipe fittings, lead solder, or brass fixtures that may contain lead, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested by a certified lab. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

**In your system, results from our lead monitoring program, conducted in accordance with the Lead and Copper Rule, were non-detectable for the presence of lead.**

# TABLE INTRODUCTION

## KEY DEFINITIONS

**ACTION LEVEL (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other required action by the water provider.

**MAXIMUM CONTAMINANT LEVEL GOAL (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MAXIMUM CONTAMINANT LEVEL (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL):** The highest level of a disinfectant allowed in drinking water. There is significant evidence that the addition of a disinfectant is necessary for control of microbial contaminants.

**TREATMENT TECHNIQUE (TT):** A required process intended to reduce the level of a contaminant in drinking water.

## STANDARD ABBREVIATIONS

NA	Not applicable
pCi/L	picoCuries per liter (measure of radioactivity)
ppb	parts per billion (micrograms per liter)
ppm	parts per million (milligrams per liter)
µg/L	Number of micrograms of substance in one liter of water

**New Mexico Water tests your water for more than 140 regulated contaminants and dozens of unregulated contaminants. This table lists only primary contaminants that were detected during the calendar year of this report (unless otherwise noted).**

See the [Potential Contaminants](#) web page for a complete list of contaminants we test for. The EPA and state of New Mexico require us to monitor for certain contaminants less than once per year because concentrations of these contaminants do not change rapidly.

## DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those with cancer undergoing chemotherapy, those who have undergone organ transplants, and those with HIV/AIDS or other immune system disorders; some elderly people; and infants, can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

Our testing equipment is so sensitive, it can detect constituents as small as 1 part per trillion. That is equivalent to 1 inch in over 15 million miles.



# 2023 WATER QUALITY

Disinfectants & Disinfectant Byproducts	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
				Low	High				
Chlorine (as CL2)	4	4	0.73	0.08	1.41	2023	ppm	No	Water additive used to control microbes
TTHMs [total trihalomethanes] <sup>1</sup>	NA	80	73	44.9	94.2	2023	ppb	No	Byproduct of drinking water chlorination
Haloacetic acids (HAA5)	NA	60	24	8.53	34.8	2023	ppb	No	Byproduct of drinking water chlorination
Inorganic Contaminants	MCLG	AL	90 <sup>th</sup> Percentile	# Samples > AL		Year Tested	Unit	Exceeds AL	Typical Source
Lead—action level at consumer taps	0	15	0	0					
Copper—action level at consumer taps	1.3	1.3	0.12	0		2023	ppm	No	Corrosion of household plumbing systems; erosion of natural deposits

## CITY OF FARMINGTON 2023 CCR DATA

Microbiological Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
				Low	High				
Turbidity (NTU) <sup>2</sup>	NA	0.3	0.6	NA	NA	2023	NTU	No	Soil runoff
Organic	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
Di(2-ethylhexyl)adipate	400	400	0.7	0.7	0.7				
Inorganic Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
Fluoride	4	4	0.6	0.56	0.6				
Barium	2	2	0.09	0.089	0.09	2023	ppm	No	Discharge of drilling wastes; discharge from metal refineries, erosion of natural deposits
Selenium	50	50	1.1	1.1	1.1	2023	ppb	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	NA	NA	27	25	27	2023	ppm	No	Erosion of natural deposits

<sup>1</sup> The average locational running annual average (LRAA) for TTHM level was 73 ppb, with a maximum level of 94.2 ppb. The MCL is calculated using the LRAA, the average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.

<sup>2</sup> 99.2% of the samples were below TT value of 0.3 NTU. A value less than 95% constitutes a TT violation. Any measurement over 1 NTU is a violation unless otherwise approved by the state. Turbidity is a measure of the cloudiness of the water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.

# 2023 WATER QUALITY

## UNREGULATED CONTAMINANT MONITORING RULE 5 (UCMR 5)

Chemical	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Low	High	Year Tested	Unit	Violation	Typical Source
Lithium	NA	NA	34.5	34.3	34.5	2023	ppb	No	Naturally occurring metals that may concentrate in brine waters; lithium salts are used as pharmaceuticals, used in electrochemical cells, batteries, and in organic syntheses.



## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER Monitoring and Reporting Requirements Not Met for Morningstar Water System

On August 9, 2023 we became aware that our system recently failed to collect the correct number of drinking water samples. Although this incident was not an emergency, as our customers, you have a right to know what happened, and what we are doing to correct the situation.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Table 1 lists the contaminants and the compliance periods which we did not monitor or test and therefore cannot be sure of the quality of our drinking water during the compliance periods.*

**TABLE 1**

Contaminant	Facility	Compliance Period
Asbestos	Distribution	2020–2022

### WHAT SHOULD YOU DO?

There is nothing you need to do. You do not need to boil your water or take other corrective actions. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

### WHAT IS BEING DONE?

New Mexico Water Service—Morningstar does not have asbestos cement piping in the system. For asbestos monitoring, compliance period is once every 9 years. At the start of the compliance period, NMED will send out a questionnaire before the beginning of the compliance period about the presence of asbestos cement piping in the system. The questionnaire was filled out incorrectly which resulted in an asbestos monitoring violation. After receiving the monitoring violation, sampling plans were updated to show that there are no asbestos cement piping. In addition, an asbestos sample was taken and the result indicated that there were no detects for asbestos in the system.

### FOR MORE INFORMATION, PLEASE CONTACT:

Staci Avendano  
(575) 744-5974  
Morningstar Water System, NM  
608 Butte Blvd  
Elephant Butte, NM 87935



Thanks for taking the time  
to learn more about your  
water quality.

Even more information awaits you at [www.newmexicowater.com](http://www.newmexicowater.com).

Visit our web site to get information about your account, water rates,  
and water system. And, as always, you can reach us by phone or at  
our Customer Center.



Quality. Service. Value.®