



# 2017 Water Quality Report

Meadow Lake Water System

Este informe contiene información muy importante sobre la calidad de su agua beber.  
Por favor lea este infome o comuníquese con alguien que pueda traducir la información.



# Table of Contents

## Your Water

Your Water System

Contact Us

Source Water Assessment and Protection

---

## 2017 Test Results

Key Definitions

Special Precautions

Possible Contaminants

About Lead

Water Quality Table

---

## More Information

Resources

## About Your Water Quality

At New Mexico Water Service (New Mexico Water), our goal is to deliver safe, high-quality drinking water, 24 hours per day, seven days per week, 365 days per year. As part of that effort, we produce this annual water quality report, which includes information about where your water comes from, what it contains, and how it compares to state and federal standards. **Most importantly, it confirms that in 2017, our water met or surpassed all standards set by the U.S. Environmental Protection Agency (EPA) and New Mexico Environment Department to protect public health.**

# Your Water System

The water for the Meadow Lake water system is pumped from three wells that are drilled into the Rio Grande Basin in an unconfined alluvial aquifer, bounded on the east by a fault at the Manzano Mountain-front and to the west by the Central Hubble Spring Fault. The groundwater pumped from the aquifer is disinfected and stored in a 250,000-gallon steel reservoir.

## CONTACT US

If you would like more information on the Meadow Lake water system or have questions about your water service, please contact your local New Mexico Water Service Customer Center:

Address: 401 Horner Street  
Rio Communities, NM 87002  
Phone: (505) 864-2218  
Hours: Monday–Friday 8 a.m.–5 p.m.  
(closed noon–1 p.m.)


## For Details on the Data in This Report

Contact:

New Mexico Water Service  
Meadow Lake Water System  
Attn: Andy Beck  
401 Horner Street  
Rio Communities, NM 87002  
(505) 864-2218 ext. 225  
Fax: (505) 864-8438  
[abeck@newmexicowater.com](mailto:abeck@newmexicowater.com)

# Source Water Assessment and Protection

The Meadow Lake water system is well maintained and operated, and sources of drinking water are generally protected from potential contamination by well construction, hydrogeology, and system operations and management. However, the susceptibility of the system is classified as “moderately high,” due to the potential contamination from septic systems. No associated contaminants have been detected from this potential source. Please contact New Mexico Water to discuss the findings for the Source Water Assessment and Protection Plan (SWAPP) report.



# Key Definitions

## Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## Maximum Contaminant Level (MCL)

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

## Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

## Maximum Residual Disinfectant Level (MRDL)

The highest level of a disinfectant allowed in drinking water. There is significant evidence that the addition of a disinfectant is necessary for control of microbial contaminants.

## Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other required action by the water provider.

## DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those with cancer undergoing chemotherapy, those who have undergone organ transplants, and those with HIV/AIDS or other immune system disorders; some elderly people; and infants, can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.



## Possible Contaminants

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

**More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at (800) 426-4791.**

The sources of drinking water (both tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

### CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems.

**Radioactive contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations also establish limits for contaminants in bottled water, which must provide the same protection for public health.

# About Lead

As the issue of lead in water continues to be top of mind for many Americans, New Mexico Water wants to assure you about the quality of your water.

*None of these conditions exist at New Mexico Water.* We have worked proactively to eliminate lead-bearing materials from our water systems, and we are compliant with health and safety codes mandating the installation of lead-free materials in public water systems. We test our water sources to ensure that the water we deliver to customers' meters meets water quality standards and is not corrosive toward plumbing materials. The water we deliver may meet lead standards, but what about your home plumbing? Because lead in drinking water comes primarily from materials and components associated with service lines and home plumbing, the Lead and Copper Rule is a critical part of our water quality monitoring program.

The Lead and Copper Rule requires us to test water *inside* a representative number of homes with plumbing most likely to contain lead and/or lead solder (those built before 1986). This test, with other water quality testing, tells us if the water is corrosive enough to cause lead from home plumbing to leach into the water. If the "Action Level" for lead is exceeded, we work with our customers to investigate the issue and, if necessary, implement corrosion control before the lead levels create a health issue.

Elevated levels of lead, if present, can cause serious health problems, especially for pregnant women and children. If your home's plumbing contains lead piping or pipe fittings, lead solder, or brass fixtures that may contain lead, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested by a lab. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

**In your system, results of our lead monitoring program, conducted in accordance with the Lead and Copper Rule, were 1.1 parts per billion. The EPA's Action Level for lead is 15 parts per billion.**

# Table Introduction

**New Mexico Water tests your water for more than 140 regulated contaminants and dozens of unregulated contaminants. This table lists only those contaminants that were detected.**

This table lists all of the drinking water contaminants that were detected during the calendar year of this report (unless otherwise noted). The EPA and state of New Mexico require us to monitor for certain contaminants less than once per year because concentrations of these contaminants do not change rapidly.

## TABLE KEY

NA	Not applicable
pCi/L	picoCuries per liter (measure of radioactivity)
ppb	parts per billion (micrograms per liter)
ppm	parts per million (milligrams per liter)
µg/L	Number of micrograms of substance in one liter of water
TT	Treatment technique



# 2017 Water Quality Table

Disinfectants & Disinfectant Byproducts	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
				Low	High				
Chlorine (as CL2)	4	4	0.81	0.36	1.8	2017	ppm	no	Water additive used to control microbes
Inorganic Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
				Low	High				
Nitrate [measured as nitrogen]	10	10	2.48	NA	2.48	2017	ppm	no	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Fluoride	4	4	0.17	NA	0.17	2017	ppm	no	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Chromium	100	100	1	NA	1	2017	ppb	no	Discharge from steel and pulp mills, erosion of natural deposits
Sodium	NA	NA	18	NA	18	2017	ppm	no	Erosion of natural deposits; leaching
Inorganic Contaminants	MCLG	AL	Your Water	Samples > AL		Year Tested	Unit	Exceeds AL	Typical Source
Lead — action level at consumer taps	0	15	1.1	0		2016	ppb	no	Corrosion of household plumbing systems; erosion of natural deposits
Copper — action level at consumer taps	1.3	1.3	0.023	0		2016	ppm	no	Corrosion of household plumbing systems; erosion of natural deposits

# Thank you.

Thanks for taking the time to learn more about your water quality! Even more information awaits you at [www.newmexicowater.com](http://www.newmexicowater.com). Visit our web site to get information about your account, water rates, and water system. And, as always, you can reach us by phone or in person at our Customer Center.

- [> Conservation & Environmental Issues](#)
- [> Calcium & Residue](#)
- [> Pharmaceuticals in Tap Water](#)

