

2020

Drinking Water Report

SANDIA KNOLLS WATER SYSTEM



Este informe contiene información muy importante sobre la calidad de su agua beber.
Por favor lea este infome o comuníquese con alguien que pueda traducir la información.

Quality. Service. Value.®

Table of Contents

YOUR WATER

Your Water System
Contact Us

2020 TEST RESULTS

Key Definitions
Special Precautions
Possible Contaminants
About Lead
Water Quality Table

MORE INFORMATION

Resources

ABOUT YOUR WATER QUALITY

At New Mexico Water Service (New Mexico Water), our goal is to deliver safe, high-quality drinking water, 24 hours per day, seven days per week, 365 days per year. As part of that effort, we produce this annual water quality report, which includes information about where your water comes from, what it contains, and how it compares to state and federal standards. **Most importantly, it confirms that in 2020, our water met or surpassed all standards set by the U.S. Environmental Protection Agency (EPA) and New Mexico Environment Department to protect public health.**

Your Water System

The water supply for the Sandia Knolls water system is pumped from two wells that are drilled into the Sandia Water Basin. The water pumped from the aquifer is disinfected and stored in four steel reservoirs that provide 200,000 gallons of storage.

SOURCE WATER ASSESSMENT AND PROTECTION

The Sandia Knolls water system is well maintained and operated, and sources of drinking water are generally protected from potential contamination by well construction, hydrogeology, and system operations and management. However, the susceptibility of the system is classified as “moderately high,” due to the potential contamination from septic systems and nearby roadways. No associated contaminants have been detected from these potential sources. Please contact New Mexico Water to discuss the findings for the Source Water Assessment and Protection Plan (SWAPP) report.

CONTACT US

If you would like more information on the Sandia Knolls water system or have questions about your water service, please contact your local New Mexico Water Service Customer Center:

Address: 401 Horner Street
Rio Communities, NM 87002
Phone: (505) 864-2218
Hours: Monday–Friday 8 a.m.–5 p.m. (closed noon–1 p.m.)

FOR DETAILS ON THE DATA IN THIS REPORT

New Mexico Water Service
Sandia Knolls Water System
Attn: Staci Avendano
401 Horner Street
Rio Communities, NM 87002
(505) 864-2218 ext. 72230
Fax: (505) 864-8438
savendano@newmexicowater.com

Key Definitions

ACTION LEVEL (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other required action by the water provider.

MAXIMUM CONTAMINANT LEVEL GOAL (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MAXIMUM CONTAMINANT LEVEL (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL): The highest level of a disinfectant allowed in drinking water. There is significant evidence that the addition of a disinfectant is necessary for control of microbial contaminants.

TREATMENT TECHNIQUE (TT): A required process intended to reduce the level of a contaminant in drinking water.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those with cancer undergoing chemotherapy, those who have undergone organ transplants, and those with HIV/AIDS or other immune system disorders; some elderly people; and infants, can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

Possible Contaminants

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at (800) 426-4791.

The sources of drinking water (both tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems.

Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations also establish limits for contaminants in bottled water, which must provide the same protection for public health.

About Lead

As the issue of lead in water continues to be top of mind for many Americans, New Mexico Water wants to assure you about the quality of your water.

None of these conditions exist at New Mexico Water. We have worked proactively to eliminate lead-bearing materials from our water systems, and we are compliant with health and safety codes mandating the installation of lead-free materials in public water systems. We test our water sources to ensure that the water we deliver to customers' meters meets water quality standards and is not corrosive toward plumbing materials. The water we deliver may meet lead standards, but what about your home plumbing? Because lead in drinking water comes primarily from materials and components associated with service lines and home plumbing, the Lead and Copper Rule is a critical part of our water quality monitoring program.

The Lead and Copper Rule requires us to test water *inside* a representative number of homes with plumbing most likely to contain lead and/or lead solder (those built before 1986). This test, with other water quality testing, tells us if the water is corrosive enough to cause lead from home plumbing to leach into the water. If the "Action Level" for lead is exceeded, we work with our customers to investigate the issue and, if necessary, implement corrosion control before the lead levels create a health issue.

Elevated levels of lead, if present, can cause serious health problems, especially for pregnant women and children. If your home's plumbing contains lead piping or pipe fittings, lead solder, or brass fixtures that may contain lead, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested by a certified lab. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

In your system, results of our lead monitoring program, conducted in accordance with the Lead and Copper Rule, were 0.5 parts per billion. The EPA's Action Level for lead is 15 parts per billion.

Table Introduction

New Mexico Water tests your water for more than 140 regulated contaminants and dozens of unregulated contaminants. This table lists only primary contaminants that were detected.

This table lists all of the drinking water contaminants that were detected during the calendar year of this report (unless otherwise noted). The EPA and state of New Mexico require us to monitor for certain contaminants less than once per year because concentrations of these contaminants do not change rapidly.

TABLE KEY

NA	Not applicable
pCi/L	picoCuries per liter (measure of radioactivity)
ppb	parts per billion (micrograms per liter)
ppm	parts per million (milligrams per liter)
µg/L	Number of micrograms of substance in one liter of water




2020 Water Quality

Disinfectants & Disinfectant Byproducts	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
				Low	High				
Chlorine (as CL2)	4	4	0.49	0.2	1.1	2020	ppm	No	Water additive used to control microbes
Inorganic Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
				Low	High				
Nitrate (measured as nitrogen)	10	10	0.85	NA	0.85	2020	ppm	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Fluoride	4	4	0.23	NA	0.23	2020	ppm	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Arsenic	0	10	1	NA	1	2020	ppm	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Chromium	100	100	0	NA	0	2020	ppb	No	Discharge from steel and pulp mills, erosion of natural deposits
Sodium	NA	NA	16	NA	16	2020	ppm	No	Erosion of natural deposits; leaching
Barium	2	2	0.024	NA	0.024	2020	ppb	No	Discharge of drilling wastes; discharge from metal refineries, erosion of natural deposits
Radioactive Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Year Tested	Unit	Violation	Typical Source
				Low	High				
Gross alpha excluding radon and uranium	0	15	2.2	22.2	2.2	2020	pCi/L	No	Erosion of natural deposits of certain minerals that are radioactive and may emit a form of radiation known as alpha radiation
Combined radium 226/228	0	5	0.08	0.08	0.08	2020	pCi/L	No	Erosion of natural deposits
Uranium	0	30	2	2	2	2020	µg/L	No	Erosion of natural deposits
Inorganic Contaminants	MCLG	AL	90 th Percentile	Samples > AL		Year Tested	Unit	Exceeds AL	Typical Source
Lead—action level at consumer taps	0	15	2.4	0		2020	ppb	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper—action level at consumer taps	1.3	1.3	0.13	0		2020	ppm	No	Corrosion of household plumbing systems; erosion of natural deposits

Thank you.

Thanks for taking the time to learn more about your water quality! Even more information awaits you at www.newmexicowater.com. Visit our web site to get information about your account, water rates, and water system. And, as always, you can reach us by phone or at our Customer Center.

- 
- A firefighter in yellow protective gear, including a tank and helmet, is shown from the side, spraying a powerful stream of water. The background is a bright, hazy sky.
- > Water quality FAQs
 - > Facts of fluoridation
 - > Potential contaminants